

## Aquarion Water Company PFAS Sampling Results

**Town/City: Woodbury**  
**Water System Name: Woodbury**

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Woodbury Well 1, POE	May 2019	2		ND		ND		ND	
	Jun. 2021	ND		ND		ND		ND	
	Sep. 2022	5	16	5	10	ND	49	ND	12
Woodbury Wells 2+3, POE	May 2019	4		7		ND		ND	
	Jul. 2021	5		10		2		ND	
	Apr. 2022	7		12		2		ND	
	Sep. 2022	12	16	22	10	4	49	ND	12

**Footnotes:**

\* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022. A yellow highlighted value denotes a concentration greater than this new level.

**Definitions:**

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.